



## **Committee of the Whole Meeting – Nov. 16, 2020 Staff Responses to Council Questions**

Before each Committee of the Whole or City Council meeting, questions that have been posed by the City Council relating to [the agenda](#) for that evening will be posted to the City's website. Below are the responses to this week's questions.

### **3. Items of Business**

#### **b. Consider Draft Resolution Authorizing Waiver of Bidding Process and Purchase Agreement for Itron Centron Meters from Anixter as Quote for Poly-Phase Meters and Single-Phase Meters Throughout Fiscal Years 2021 and 2022, Not-to-Exceed the Budgeted Amount Per Year for Each Year**

*Q: COW Page 42 The response to our request for a quote indicates that the meter with the ERT module is obsolete and discontinued. Will this present a larger problem in future years? Is there a different technology that is being supported that the City should consider migrating to?*

*A: The older build of the ERT module is what was discontinued. The meters are still in production with a new build of the ERT module installed. With the new design ERT module, ITRON has indicated they are going to supporting the fixed network into the future. However, at present, third-party ERT modules are no longer available.*

#### **d. Consider Draft Resolution Relating to Commuter Parking Fees and Permits**

*Q: Page 50 - Is the reference to the \$1.3M cash balance in the fund before or after the paydown of the parking fund debt?*

*A: This is the cash balance after having paid down the debt.*

**Public Comments - None**